



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA250967

Certificate Holder: 3A Australia Lighting Pty Ltd
Unit 3/48-50 Fitzpatrick Street
Revesby NSW 2212
Australia

Regulatory Definition: Non-Declared

Product Description: LED Downlight

Standard/s: AS/NZS 60598.2.2:2016 Inc A1:2017 A2:2021
AS/NZS 60598.1:2017 Inc A1:2017 A2:2020

Condition/s: For use with suitable Australian-approved independent SELV
power supply only (GMA-513534-EA, GMA-512776-EA)

Approval Marks: SAA250967

Initial Issue Date: 24 July 2025

Expiry Date: 24 July 2030


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 1 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL1560-WH5C10S01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1560-SC5C10S01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1560-BK5C10S01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1570-WH5C10S02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1570-SC5C10S02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1570-BK5C10S02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1571-BKTC13S02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 2 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL1571-SCTC13S02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1571-WHTC13S02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1561-WHTC13S01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1561-SCTC13S01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1561-BKTC13S01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9454-WHTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9454-BKTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1757-WHTC12C02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 3 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL1757-BKTC12C02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1756-WHTC12C02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1756-BKTC12C02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9455-WHTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9455-BKTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9416-WHTC10C02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9416-BKTC10C02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9415-WHTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 4 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL9415-BKTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9411-WH3K10C01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9411-WH4K10C01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9411-BK3K10C01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9411-BK4K10C01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9452-WHTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9452-BKTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9452-WH+SLTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 5 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL9452-WH+BKTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9452-WH+GDTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9452-BK+GDTC10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9453-WH3K10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9453-BK3K10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9453-WH4K10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL9453-BK4K10C03	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DLJ103-WH3K10C02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 6 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL20096-BKTC20S01S	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL106-WHTC10S01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL106-BKTC10S01	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1019-WHTC15S01	3A LIGHTING	36Vdc15W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1019-BKTC15S01	3A LIGHTING	36Vdc 15W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL2009-WHTC20S01	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL2009-BKTC20S01	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL3009-WHTC30S01	3A LIGHTING	36Vdc 30W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 7 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL3009-BKTC30S01	3A LIGHTING	36Vdc 30W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL4009-WHTC40S01	3A LIGHTING	36Vdc 40W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL4009-BKTC40S01	3A LIGHTING	36Vdc 40W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL5000-WHTC50S01	3A LIGHTING	36Vdc 50W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL5000-BKTC50S01	3A LIGHTING	36Vdc 50W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL4001-WHTCDPS02	3A LIGHTING	36Vdc 40W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL4001-BKTC DPS02	3A LIGHTING	36Vdc 40W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL2005-WHTC20C02	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 8 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL2005-BKTC20C02	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL3005-WHTC30C02	3A LIGHTING	36Vdc 30W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL3005-BKTC30C02	3A LIGHTING	36Vdc 30W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL5001-WHTC60S02	3A LIGHTING	36Vdc 60W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL5001-BKTC60S02	3A LIGHTING	36Vdc 60W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
SFR006-WHTC3832S01	3A LIGHTING	36Vdc 38W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
SFR006-BKTC3832S01	3A LIGHTING	36Vdc 38W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL2503-WHTC20C02	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 9 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL3503-WHTC30C02	3A LIGHTING	36Vdc 30W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
SFS009-WHTC3832S01	3A LIGHTING	36Vdc 38W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
SFS009-BKTC3832S01	3A LIGHTING	36Vdc 38W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DD1010M-WHTC10C02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DD1010M-BKTC10C02	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DD1810M-WHTC2010C02	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DD1810M-BKTC2010C02	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DD2810M-WHTC30C02	3A LIGHTING	36Vdc 30W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 10 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DD2810M-BKTC30C02	3A LIGHTING	36Vdc 30W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DLV320-WHTC7C02	3A LIGHTING	36Vdc 7W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DLV320-BKTC7C02	3A LIGHTING	36Vdc 7W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DLV325-WHTC12C02	3A LIGHTING	36Vdc 12W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DLV325-BKTC12C02	3A LIGHTING	36Vdc 12W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL13-BK3K3S03	3A LIGHTING	3Vdc 3W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL13-BK4K3S03	3A LIGHTING	3Vdc 3W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL23-WH3K3S03	3A LIGHTING	3Vdc 3W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 11 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL23-WH4K3S03	3A LIGHTING	3Vdc 3W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1071-WHTC10S0	3A LIGHTING	36Vdc 10W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
AL5006-WHTC7S02-TS	3A LIGHTING	36Vdc 7W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
AL5008-WHTC12S02-TS	3A LIGHTING	36Vdc 12W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
AL5009-WHTC15S02-TS	3A LIGHTING	36Vdc 15W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
AL5010-WHTC18S02-TS	3A LIGHTING	36Vdc 18W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
AL5011-WHTC24S02-TS	3A LIGHTING	36Vdc 24W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL108-WHTC7S03	3A LIGHTING	36Vdc 7W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 12 of 13



A P P R O V A L S ®

Certificate of Suitability

Model	Trade Name	Rating/Marking
DL108-BKTC7S03	3A LIGHTING	36Vdc 7W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1008-WHTC12S03	3A LIGHTING	36Vdc 12W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL1008-BKTC12S03	3A LIGHTING	36Vdc 12W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL2008-WHTC20S03	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL2008-BKTC20S03	3A LIGHTING	36Vdc 20W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL3008-WHTC35S03	3A LIGHTING	36Vdc 35W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)
DL3008-BKTC35S03	3A LIGHTING	36Vdc 35W ta:40°C, Class III IP20 (for parts recessed in ceiling) IP54 (for parts outside ceiling only)

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 24-07-25 250967
Page 13 of 13